

On behalf of The Town of Waynesville, North Carolina
IBR for Main Street Pavilion

ADDENDUM I

March 24, 2022

Acknowledgment of receipt of Addenda must be included with sealed Bid. Include an initialed copy of each addendum with your submission.

Initials: _____ Company: _____

Vendors are informed that the above referenced subject is hereby modified, corrected, or supplemented as specified, described, and set forth in this Addendum:

- 1. The Town of Waynesville shall provide two reserved parking spaces adjacent to the construction zone along Miller Street for the purpose of providing onsite dumpsters and porta johns by the Contractor for the duration of the project.**
- 2. The recessed can lighting referred to in the bid documents shall consist of four exterior grade can lights attached to the trusses of the structure. Power service for this lighting shall be pulled from "Electrical Panel B" which is located adjacent to the proposed construction site. Power service will be ran by the contractor under the supervision of the Town's Electric Department.**
- 3. The Town shall be responsible for relocating any onsite utilities that require relocation. The Town shall be responsible for any road closures required by the contractor in order to carry out the contract.**

Any and all questions regarding this Bid should be addressed to:

**Jesse Fowler
Assistant Town Manager
(828) 452-2491
jfowler@waynesvillenc.gov**